office printable .com

EXTINGUISHER MAINTENANCE REGISTER

BUILDING / SITE | RESPONSIBLE PERSON | SERVICE CONTRACTOR / LICENSE | REGISTER UPDATED

ID	Location	Type / size	Serial	Mfg. date	Last annual	Next annual	6-yr maint.	Hydro test	Hydro due	Cert. no.	Status / notes

NFPA 10 intervals: annual maintenance every 12 months; internal examination at 6 years for stored-pressure dry chemical; hydrostatic test every 12 years for dry chemical and most stored-pressure types, every 5 years for CO2, water, foam and wet chemical. Follow the manufacturer and your authority having jurisdiction where they differ.